


1. PRODUCT	FLOORING HYDRAULIC DOOR-CLOSER FOR PEDESTRIAN DOORS
2. REFERENCE	CTS800-4
3. USE	Fire doors, anti-smoke and / or evacuation routes
4. MANUFACTURER	INTHER SYSTEMS EUROPE, S.A. Calle Travesía Nº 5, Nave nº 16 y 17 46220, Picassent, Valencia – Spain
5. EVALUATION SYSTEM	SYSTEM 1
6. NOTIFY BODY NUMBER	WARRINGTON / Nº 1121
7. NUMBER OF CERTIFICATION	1121-CPR-AD5391
8. DECLARED PERFORMANCE	EN 1154:1996/A1:2002/AC:2006 Building hardware. Controlled door closing devices. Requirements and test methods  CATEGORY OF USE: Close from 105º DURABILITY: 500.000 cycles DOOR-CLOSER FORCE: Force 4 FIRE-RESISTANCE: Suitable for fire doors and / or smoke-doors PERSONAL SAFETY: Suitable CORROSION RESISTANCE: Very high corrosion resistance (240 hours)
9. DANGEROUS SUBSTANCES	The materials of the products do not contain or release any dangerous substance in excess of the maximum specified in European standards in normal use levels.
10. RESPONSABILITY	This declaration of performance is issued under the sole responsibility of INTHER SYSTEMS EUROPE, S.A., Ensuring compliance with the declared performances of the specified product.
Valencia, August 06, 2016	 INTHER SYSTEMS EUROPE, S.A.