



<b>1. PRODUCT</b>	HYDRAULIC DOOR-CLOSER FOR PEDESTRIAN DOORS
<b>2. REFERENCE</b>	CTB 81
<b>3. USE</b>	Fire doors, anti-smoke and / or evacuation routes
<b>4. MANUFACTURER</b>	<b>INTHER SYSTEMS EUROPE, S.A.</b> Calle Travesía Nº 5, Nave nº 16 y 17 46220, Picassent, Valencia – Spain
<b>5. EVALUATION SYSTEM</b>	SYSTEM 1
<b>6. NOTIFY BODY NUMBER</b>	Element Materials Technology Rooterdam B.V. / Nº 2812
<b>7. NUMBER OF CERTIFICATION</b>	2812-CPR-AD5260
<b>8. DECLARED PERFORMANCE</b>	<p><b>EN 1154:1996/A1:2002/AC:2006</b> Building hardware. Controlled door closing devices. Requirements and test methods</p>  <p>The diagram shows a CE mark on the left and a performance diagram on the right. The diagram consists of six boxes with numbers: 4, 8, 2/6, 1*, 1, and 3. Lines connect these boxes to the corresponding performance categories on the left:</p> <ul style="list-style-type: none"> <li>4: Close from 180°</li> <li>8: 500.000 cycles</li> <li>2/6: Force 2/6</li> <li>1*: Suitable for fire doors and / or smoke-doors</li> <li>1: Suitable</li> <li>3: High corrosion resistance (96 hours)</li> </ul>
<b>9. DANGEROUS SUBSTANCES</b>	The materials of the products do not contain or release any dangerous substance in excess of the maximum specified in European standards in normal use levels.
<b>10. RESPONSABILITY</b>	This declaration of performance is issued under the sole responsibility of INTHER SYSTEMS EUROPE, S.A., Ensuring compliance with the declared performances of the specified product.
Valencia, 30 November 2020	 <b>INTHER SYSTEMS EUROPE, S.A.</b>